

! CAUTION

- All wiring should be done by a licensed electrician in accordance with state codes, local codes and National Electric Code (NEC) standards.
- Improper installation may result in serious injury and void warranty.
- Contains parts and assemblies susceptible to damage by electrostatic discharge (ESD).

! IMPORTANT SAFEGUARDS

- **Warning:** When using portable luminaires, basic safety precautions should always be followed including the following:
 - Read and follow all safety instructions.
 - When used in wet locations, Ground Fault Circuit Interrupter (GFCI) protection is to be provided on the circuit(s) or outlet(s) to be used for the luminaire. Receptacles are available having built-in GFCI protection and are able to be used for this measure of safety.
 - **Caution - Risk of Electric Shock.** Do not use with extension cord near water or where water may accumulate. Keep lamp at least 16 feet from pools and spas. Keep plugs and receptacles dry. For use only on GFCI protected circuits.
 - Max distance to the receptacle is determined by the length of the cord provided.

Save these instructions.

Retrofitting the Lens on an Installed DLA Series docklite[®] Head

1. Disconnect all power to existing dock lite.
2. Remove dock lite head from arm.
3. Hold dock lite head in stationary position. For best results, use a vice to secure the fixture.
4. Using a ¼ inch metal bar (not included), loosen current lens assembly by inserting metal bar in lens grooves and rotating counterclockwise (see Figure 1). Once loose, continue to unscrew lens assembly by hand, and then discard it.
5. Screw in replacement lens assembly, turning clockwise, and tighten using ¼ inch metal bar (not included) until you cannot turn it any further. (Lens assembly will fit tightly against dock lite housing.)
6. Remove dock lite head from vice and mount on arm.
7. Restore power and position light in desired location.

Figure 1

